

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7125-0026:316

Page 1 of 1

CATEGORY: Fire Alarm Devices for the Hearing Impaired

LISTEE: Simplex, 100 Simplex Drive, Westminter, MA 01441-0001
Contact: Paul Mattern (978) 731-8542 Fax (978) 731-8881

DESIGN: Models 4906-9101, -9102, -9103, and -9104 multi-candela, non-addressable, synchronizable strobe lights. Models 4906-9101 and -9103 are for wall mount. Models 4906-9102 and -9104 are for ceiling mount. Synchronizing modules are required for synchronizing strobe lights if the interconnected control unit does not provide NAC synchronization capabilities. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Electrical: 16-33 VDC
Candela: 15, 30, 75, and 110 cd

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as strobe lights for use with separately listed compatible fire alarm control units. For indoor use only. Refer to listee's Installation Instruction Manual for details.

These units can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition.

06-23-04



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 30, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**